

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. _____ Dated 07/08/2024
 It is certified that an inspection team headed by Mr. Rajiv Gaikwad
 (Name of Officers with designation) from Assistant Engineer, Sub Division PHED, Ujjain
 inspected the The Divine Public School, at Nagziri, Dewas Road, Ujjain (MP) on 07/08/2024
 (date of inspection) and on the basis of Water Test Report (Attached) bearing no 12 dated
 07/08/2024 of Water Testing Laboratory, Ujjain (PHED Lab) certified that the The Divine Public
School has safe drinking water facilities for the students and members of staff of the institution.
 School is also maintains the hygienic sanitation condition in the school building & the campus as per
 norms prescribed by the Central/ State/ U.T. Govt.
 This certificate is valid till 03 Year.

Assistant Engineer
 P.H.E. Maint. Sub Div. No. 2
 N.P.N. Ujjain (M.P.)
 Signature with Seal: _____
 Name: Mr. Rajiv Gaikwad
 Designation: _____
 Name & Address of the Office / Department: _____

To
 The Divine Public School,
 Nagziri, Dewas Road, Ujjain (MP)

Biological

Bacteriological (M.P.N.) of coli form per 100 ml of sample - No. 1) NIL ✓

Special Tests

- (1)
- (2)
- (3)

Chemist :

Remarks : All the tested parameter results are under limits as per CPHEEO manual.

So, Water can be used for the drinking purpose. ✓

Assistant Engineer
 P.H.E. Maint. Sub Div. No. 2
 N.P.N. Ujjain (M.P.)

WATER TREATMENT PLANT & LAB
 LABORATORY UJJAIN
 P.H.E. N.P.N. UJJAIN
 FILTRATION PLANT
 GAU GHAT, UJJAIN

Note :
 East :

ON INDIA GOVERNMENT SERVICE

✓ To,

STAMP

No. _____
 The Divine Public School
 Nagziri
 Ujjain

LABORATORY
 PUBLIC HEALTH ENGINEERING DEPARTMENT
 MAINTENANCE SUB DIVISION NO. 2, P.H.E. DEPTT., UJJAIN

Sample from : The Divine Public School, Nagziri, Ujjain
 Particular of sample : Sample No. 1) R.O. Water
 Date of collection : 07-08-24
 Date of Analysis : 07-08-24

S. No.	Characteristics	Unit	Appendix		Result					
			As per manual on water supply Treatment prepared published by CPHEEO- Manual		R.O. Water					
			Acceptable	Cause for rejection	①	2	3	4	5	6
1.	Physical Turbidity	NTU	2.5	10.0	00	✓				
2.	Colour	PCobalt	5.0	25.0	NIL	✓				
3	Taste and odour	Scale	Unobjectionable	Unobjectionable	NIL	✓				
4.	PH	PH Scale	7.0 to 8.5	<6.5 to 9.2>	7.02	✓				
5.	Total Alkalinity	Mg/l	200	600	080	✓				
6.	Chloride	-	Up to 200	1000	048	✓				
7.	Total Hardness	Mg/l	200as CaCO3	600as CaCO3	072	✓				
8.	Calcium Hardness	-				✓				
9.	Magnesium Hard.	-				✓				
10.	Total Dissolved Solids	-	500	2000	100	✓				
11.	Iron	Mg/l	0.1	1.0	NIL	✓				
12.	Fluride	-	1.0	1.5	NIL	✓				
13.	Maganese	-	0.3	1.0	-	✓				
14.	Dissolved oxygen	-	-	-	-	✓				
15.	C.O.D.	-	10	-	-	✓				
16.	B.O.D.	-	06	-	-	✓				
17.	Residual Chlorine	-	02	1.0	NIL	✓				
18.	Coagulant dose At test	-	-	-	-	✓				

Note : 1. The figure indicated under the column acceptable are the limits upto which the water is generally Acceptable to the consumers.
 2. Figure in excess to those mentioned under acceptable render the water not acceptable but still Tolerated in the absence of alternative and better source but upto the limits indicated under Column 'cause for rejection' above which the supply will have to be rejected.